

MICRO-CARBON[®]4

FILTRATION SYSTEM

4617-24
(46170)

For control of sediment* and objectionable taste and odor in water fountains, beverage equipment, coffee making equipment and similar equipment. DO NOT USE WITH WATER THAT IS MICROBIOLOGICALLY UNSAFE OR WITH WATER OF UNKNOWN QUALITY WITHOUT ADEQUATE DISINFECTION BEFORE OR AFTER THE UNIT.

Be sure Direction of FLOW is correct 

HOW TO INSTALL

*Based on manufacturer's Internal testing.

This system may be installed in any convenient location. Be sure to keep the Micro Carbon Unit away from any heat source.

1. Shut water off and cut water line where the Micro-Carbon Unit is to be installed.
2. Attach the Micro-Carbon Unit to water lines using flare or compression fittings. Unit is molded with 1/4" FPT. If desired, quick connect couplers may be used, attaching the QC plug to the Micro-Carbon. Do not over tighten fittings.
3. Turn water on and flush 5 to 6 gallons of water or until clear.
4. Mark date of installation below: replace unit after 5-6 months.

Rated Service Life	Flow-Rate	Min. Press.	Max. Press.	Max. Temp.
1500 gals.	0.5 gpm	20 psi	125 psi	100°F

Distributed by:



2611 Schuetz Road • St. Louis, Missouri 63043
800-554-5499 • www.nucalgon.com

SH247129 (1209)

CALGON is a licensed trade name

Made in U.S.A.

DATE OF INSTALLATION: _____