

Nu-Plus HZ-S

**Scale Inhibitor, Taste
& Odor Reduction,
Sediment Reduction**

Nu-Plus HZ-S

**Scale Inhibitor, Taste
& Odor Reduction,
Sediment Reduction**

Date Installed

SPECIFICATIONS

0.5 micron
2.1 gpm
12 Months or 29,000 gal

This product is covered by the following patent:
US D704,554



Tested and Certified by NSF International against NSF/ANSI Standard 42 for the reduction of claims specified on the performance data sheet.



2611 Schuetz Road
St. Louis, MO 63043
800-554-5499

www.nucalgon.com

Calgon is a licensed trade name.
(0922)



INSTALLATION INSTRUCTIONS

1. Turn off inlet water supply.
2. Open the system flush valve to relieve pressure.
3. Remove used filters by rotating them 1/4 turn to the left (clockwise) and then gently pulling down.
4. Insert new filter in to the manifold and turn 1/4 turn to the right (counterclockwise) until the filter stops.
5. Turn on water supply, water will flush out the system valve.
6. Flush the cartridge for five minutes.
7. Close the flush valve and open water line/ turn on power to equipment.

Flow rate and filter capacity refer to the individual filter only. For systems containing multiple filters, refer to the system installation manual for specifications.

Replace the cartridge annually to ensure the continued reduction of lime and scale build up. The cartridge capacity may vary according to flow rate, inlet line pressure and local water conditions, which may require more frequent cartridge replacement.

Check for compliance with state and local laws and regulations. Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. The contaminants or substances reduced by this filter are not necessarily in your water. Not for residential use. Foodservice applications only. For additional product information, please refer to aquamor.com.

To be serviced by an authorized professional.

